Cooling Large Telescopes and Instruments to 4 K Using Adiabatic Demagnetization Refrigerators

Sally House, NASA Academy Research Associate*, Summer 2003
Principal Investigator: Dr. Mike DiPirro*
Co-Investigators: Dr. Ed Canavan*, Dr. Peter Shirron*, Dr. Jim Tuttle*,
and Dr. Todd King**

*Code 552, NASA Goddard Space Flight Center, Greenbelt, Maryland


*Code 552, NASA Goddard Space Flight Center, Greenbelt, Maryland **Code 541, NASA Goddard Space Flight Center, Greenbelt, Maryland

Introduction

- Cooling detectors improves the quality of the data obtained by reducing the noise due to heat energy.
- An Adiabatic Demagnetization Refrigerator (ADR) is a type of cooler that has a high efficiency at low temperatures and is frequently used in space missions.
- An ADR contains a magnetocaloric material, which absorbs thermal energy in the presence of a low magnetic field and releases it in a high magnetic field.
- It is necessary to confine the magnetic fields produced in an ADR to ensure that there is no interference with spacecraft operations.
- The magnetocaloric material used in an ADR is chosen partly for its cooling capacity.

Specific Research


- A relatively large 4 K cooling power is needed for large aperture telescopes.
- A toroidal arrangement of coils producing a magnetic field requires minimal magnetic shielding.
- Gadolinium fluoride may be a suitable magnetocaloric material for use in an ADR.




Magnetic Fields of Equal Cooling Power Toroid vs. Solenoid

101
100
100
1001
1001
1003
1004
1005
1004
1005
Distance from Center (Meters)

Fringing field of "toroid" made up of eight solenoids





Segmented toroid field profile

Individual Contribution

The heat capacity of gadolinium fluoride will be determined at several constant magnetic fields. This will be done by measuring the temperature increase resulting from the addition of a known amount of heat. Results are not yet available.